



## **Norwich Pavilion**

Bid Addendum 3

Issue Date – 10/30/2018

### **To All Bidders:**

This addendum amends or supplements the original specifications, related documents, and previous addendums for this project. Please include a copy of this addendum with your bid submission to prove receipt of Addendum No.3 and its terms.

Issued herewith are the following items:

### **List of Contractor RFIs**

ITEM 1: See enclosed RFI Log

**This amendment shall be considered in submitting your bid and shall be attached to the bid proposal and made a part thereof.**

# Norwich Pavilion

## RFI Log

Item	Date Initiated	Discipline	Description	Reply
1	10/29/18		Section 321400 page 3 or 6- States 50 year warranty on all wood. He said this is not something that most companies can offer.	Wood Warranty to be 5 years
2	10/29/18		Paint Specs and finish schedule for what gets painted.	All visible framing and plywood is to receive 1 coat of primer, and 2 coats of paint. Paint and Primer is to be water based acrylic alkyd, semi-gloss finish. Sherwin Williams, or equal. Exact white color TBD. Allow treated lumber to dry as required by the paint manufacturer prior to priming and painting.
3	10/29/18		Is the service a single phase or three phase?	Single Phase
4	10/29/18		Coded note 4 on L-501 calls out for a total of 16 receptacles. However, there are only 8 shown on the plan. Where are the remaining 8 receptacles to be located?	8 receptacles are shown on the plan and the other 8 are on the H Frame Panel.

**Addendum No. 3 Issued 10/30/2018**